



UNIVERSAL ENGINEERING SCIENCES

Consultants In: Geotechnical Engineering • Environmental Sciences
Geophysical Services • Construction Materials Testing • Threshold Inspection
Building Inspection • Plan Review • Building Code Administration

LOCATIONS:

- Atlanta
- Daytona Beach
- Fort Myers
- Fort Pierce
- Gainesville
- Jacksonville
- Miami
- Ocala
- Orlando (Headquarters)
- Palm Coast
- Panama City
- Pensacola
- Rockledge
- Sarasota
- Tampa
- Tifton
- West Palm Beach

Client: Razorback Mining Co.
5608 SR 74
Wimauma, Florida 33598



Project No.: 0810.2200106.000
Report No.: LBR#1
Workorder No.: N/A
Report Date: August 29, 2022

Project: Razorback II
1006 Leonard Lee Rd.
Wimauma, Florida 33598

LIMEROCK BEARING RATIO REPORT FM 5-515

Date Sampled: 8/23/2022
Date Tested: 8/26/2022
Date Penetrated: 8/28/2022

Sampled By: J. Taunton
Sample: 15302
Location: Cell 1



This form may not be reproduced without the consent of UES, LLC

Maximum Density: 107.6
Optimum Moisture: 13.6
Maximum LBR: 41
Required LBR: 40
Soil Description: Chert Rock Br

This report has been reviewed by the UES Engineer of Record. The intent of this report is to provide testing information in an Expeditious manner. A signed / sealed cover page for all tests reports can be provided at the completion of the project and / or at the request of the client.

© 2019