

Client: BlueForge LLC
 5608 SR 674
 Wimauma, Florida 33598


Project No.: 0810.2200106.0000
Report No.: PR#1
Date: February 15, 2024

Project: Razorback 2
 Wimauma, Florida

MODIFIED PROCTOR ASTM D 1557

Date Sampled: 2/9/2024
Date Tested: 2/13/2024
Workorder No.:

Tested By: J Haney
Sample No.: 16824
Rammer Type: Mechanical



Proctor	
Maximum Density (pcf)	109.8
Optimum Moisture (%)	10.7
Soil Classification	
Percent Passing 200 (ASTM D1140)	8.90
Soil Classification (ASTM D2487)	N/A
Plasticity Index (ASTM D4318)	N/A
pH (FM-5-550)	6.77
Organic Content (ASTM D2974)	0.4

Soil Description: Light Brown Sand
Location: SW Corner

This report has been reviewed by the UES Engineer of Record. The intent of this report is to provide testing information in an Expeditious manner. A signed / sealed cover page for all tests reports can be provided at the completion of the project and / or at the request of the client.

This form may not be reproduced without the consent of UES, LLC.

© 2022



Materials Testing
 Geotechnical Engineering
 Environmental
 Building Sciences & Safety
 Inspections & Code Compliance
 Virtual Design Consulting

Client: BlueForge, LLC
 5608 SR674
 Wimauma, Florida 33598

Project No.: 0810.2200106.0000
Report No.: SSA#1
Date: February 14, 2024

Project: Razorback II

REPORT ON SIEVE ANALYSIS OF FINE AGGREGATES

Date Sampled: 02/09/24
Date Tested: 02/13/24
Workorder Number: N/A

Sampled By: J. Taunton (Client)
Tested By: C. Fish
Sample Number: 16824

Dry Weight of Original Sample (grams): 129.18

Sieve Size	Weight on Sieve (g)	Accumulative Weight (g)	Percent Retained	Percent Passing	Percent Passing Specification	Comments
4		0.00	0%	100%		
10		0.0	0%	100%		
40		6.8	5%	95%		
60		36.1	28%	72%		
100		79.1	61%	39%		
200		127.1	98.4%	1.6%		
PAN		129.2	100%	0%		

Fineness Modulus

N/A

Reviewed By,
Universal Engineering Sciences, LLC
 Certificate of Authorization No. 00000549

Mark K. Hardy, P.E.
 Tampa Branch Manager
 Professional Engineer No. 57233
 Date: _____

This form may not be reproduced without the consent of UES, LLC

© 2016